

Blakeney Sailing Club

Risk assessment – Petrol Storage

This Risk Assessment reviews the main hazards associated with storage of petrol used for Patrol Boats and details the measures taken to mitigate against them. It is therefore expected that all event participants are aware of these measures and abide with them.

The measures in this Risk Assessment enable compliance with The Petroleum (Consolidation) Regulations 2014 concerned with preventing or limiting the risk of fire and / or explosion from a highly flammable liquid / vapour. Norfolk Fire and Rescue Service has been notified of the storage of petrol which is required annually.

The following are risks have been identified:

Risk	Control Measures
1. Explosion, fire, burns, death from 44 Litres (maximum) of petrol stored in Club hut.	Petrol stored in approved containers and in a locked store. Containers to be regularly checked for leaks Petrol containers must be placed on the ground when being filled. Adequate ventilation to be maintained at all times, no sources of ignition / heat likely to ignite petrol or vapour to be stored in hut.